

1. Supplement

(Supplement according to EC-Directive 94/9 Annex III letter 6)

ZELM ex

to EC-type-examination Certificate

ZELM 05 ATEX 0279 X

Equipment: **axial fan type AW...**
Manufacturer: **Systemair GmbH**
Address: **D-97944 Windischbuch**

Description of supplement

The 1. Supplement concerns compliance of the equipment in line with the described variants, as shown in the documentation, to the below mentioned standards:

- AW 355D4-2-EX
- AW 420D4-2-EX
- AW 550D6-2-EX
- AW 650D6-2-EX

The marking is in future:

 II 2G c Ex e IIB T1, resp. T2, resp. T3, resp. T4

The axial fans in future are equipped with three-phase ac motors of the type series MK 106-.D... with EC-type-examination certificate PTB 08 ATEX 3061. The „electrical data“ remain unchanged. The special conditions for safe use are also not changed, and are valid also for this 1. Supplement.

Report No.

ZELM Ex 1441011873

Essential Health and Safety Requirements

The essential health and safety requirements are still fulfilled by compliance with the following Standards:

EN 13463-1:2009
EN 60079-0:2006

EN 13463-5:2003
EN 60079-7:2007

EN 14986:2007

ZELM ex

**Zertifizierungs-
stelle**

Braunschweig, 2011-11-01


Zertifizierungsstelle ZELM EX
Dipl.-Ing. Harald Zelm

**ZELM
ex**

Sheet 1 of 1

EC-type-examination Certificates without signature and stamp are not valid. This EC-type-examination Certificate may only be circulated without alteration. Extracts or alterations are subject to approval by the Prüf- und Zertifizierungsstelle ZELM EX. This English version is based on the German text. In the case of dispute, the German text shall prevail.

ZELM ex
Prüf- und Zertifizierungsstelle
Siekgraben 56 · D-38124 Braunschweig