



التاريخ: 2014 / 08 / 04

الرقم: م.ط/وق/ 150 / ٢٧٨

الإدارة العامة للإطفاء
Kuwait Fire Service Directorate

المحترمين

السادة / شركة فواز للتبريد وتكييف الهواء

تحية طيبة وبعد ،،،

الموضوع: تجديد اعتماد معدات نظام إنذار الحريق

صنع الشركة الكندية Secutron Inc

بالإشارة إلى الموضوع أعلاه ، وردا على طلبكم المؤرخ في 2014/06/22 ، وبعد دراسة الكالوجات الفنية والشهادات

المقدمة من المختبر الأمريكي UL ، نود أن نعلمكم بأنه لا مانع لدينا من تجديد اعتماد معدات نظام إنذار الحريق صنع الشركة الكندية

المذكورة حسب البيانات الواردة في الجداول التالية.

S. No.	Model	Description	UL
1	MR-2100	1 Loop Addressable Panel	S6610
2	MR-2200	2 Loop Addressable Panel	S6619
3	MR-2900	2-16 Loop Addressable Panel 2-24 Zone Conventional Panel	S6619
4	MR-2920	2-16 Loop Addressable Panel Thermal Printer 2-24 Zone Conventional Panel	S6619
5	MR-2614	Remote LED Annunciator	S8690
6	MR-2944	Addressable Repeater Panel	S8690
7	MR-2602	2 Zone Fire Alarm Control Panel	S6619
8	MR-2605	5 Zone Fire Alarm Control Panel	S6619
9	MR-2306	6 Zone Fire Alarm Control Panel	S6619
10	MR-2312	12 Zone Fire Alarm Control Panel	S6619





التاريخ: 2014 / 08 / 04

الرقم: مط/وق/ 150 / ٢٧٨

الإدارة العامة للإطفاء
Kuwait Fire Service Directorate

S. No.	Secutron Models	Wheel Lock Model	Description	UL
11	MRA-MT24WMR	MT24WMR	Multi-Tone C/w Strobe	E5946
12	MRA-MBG6-24R	MBG6-24R	6" Bell 24 VCD	E5946
13	MRA-MBG10-24R	MBG10-24R	10" Bell 24 VCD	E5946
14	MRA-MT 12/24R	MT 12/24R	Multi-Tone Siren	E5946
15	MT4 12/24R	MT4 12/24R	Multi-Tone Siren	E5946
16	MRA-WBB-R	WBB-R	Standard Outdoor Back Box	E5946
17	MRA-BBR	BB	Standard Indoor Back Box	E5946

S. No.	Secutron Models	System Sensor Model	Description	UL
18	MRI-1251B	1251B	Intelligent Analogue Addressable Ionization Detector	S911
19	MRI-2251B	2251B	Intelligent Analogue Addressable Photoelectric Detector	S911
20	MRI-2251TB	2251TB	Intelligent Analogue Addressable Multi-Sensor Detector	S911
21	Beam 200	Beam 200	Addressable Beam Detector	S911
22	MRI-5251	5251	Intelligent Analogue Addressable Heat Detector	S2101
23	MRI-DH500	DH500	Addressable Air Duct Housing to be used with MRI-1551 Intelligent Analogue Addressable	S6487
24	DNR	DNR	Addressable Air Duct Housing to be used with MRI-2251B	S911
25	MRI-B501	B501	Flanged Base 6.1" Dia for Addressable Detectors	S911
26	MRI-B501	B501	Flanged Base 4" Dia for Addressable Detectors	S911
27	MRD-1451	1451	Conventional Ionization Smoke Detector	S911
28	MRD-2151	2151	Conventional Photoelectric Smoke Detector	S911





التاريخ: 2014 / 08 / 04

الرقم: م.ط/وق/ 150 / 2014

الإدارة العامة للإطفاء
Kuwait Fire Service Directorate

S. No.	Secutron Models	System Sensor Model	Description	UL
29	MRD-5451	5451	Conventional Heat Detector	S2101
30	MRD-RA400Z	RA400Z	Remote Lamp (Indicator)	S2522
31	MRD-B401	B401	Base for Conventional Detector	S911
32	MRI-M500M	M500M	Monitor Modules (Interface)	S8690

S. No.	Secutron Models	System Sensor Model	Description	UL
33	MRI-M501M	M501M	Monitor Modules Compact Design	S8690
34	MRI-M500R	M500R	Control Module (Interface)	S8690
35	MRI-500X	M500X	Isolator Module (Interface)	S8690
36	MRM-701U	701U	Manual Pull station	S6492
37	MRM-700WP	700WP	Weather Proof Surface Mount Back Box	S6492
38	RMS-EX-WP-6T		Explosion Proof Manual Pull Station	E19040

S. No.	Secutron Models	Kac Model	Description	LPCB
39	MCP5A-RP01-FG	MCP5A-RP01-FG	Addressable Flush Mount Manual Call Point	LPCB 166/45
40	MCP1A-R470SF	MCP1A-R470SF	Conventional Manual Call Point Surface Mount	LPCB 166/39





التاريخ، 2014 / 08 / 04

الرقم، م ط / وق / 150 / ٢٧٢

الإدارة العامة للإطفاء
Kuwait Fire Service Directorate

S. No.	Secutron Models	Mgc	Description	LPCB
41	SD-2WP	SD-2WP	Conventional Smoke Detector	S6295

S. No.	Secutron Models	Mgc
42	P2R	Horn & Strobe

شرطة التقييد بجميع لوائح ومواصفات الإدارة العامة للإطفاء الخاصة بتجارة وصيانة معدات وأنظمة الإنذار والمكافحة وتوفير قطع الغيار وعمل الصيانة اللازمة لها ، حيث يجب توفير اسم وموديل المعدة وأيضا اسم وشعار المختبر ورقم التسجيل على المعدة ، وتقديم الكالوجات الفنية للدراسة والاعتماد لكل مشروع على حده قبل التنفيذ . علما بأن هذه الموافقة صالحة لمدة سنتين من تاريخه .

وتفضلوا بقبول فائق الاحترام ،،،

نائب المدير العام لشؤون الوقاية /

سلافة جمعة الياسين
مدير إدارة التراخيص

نسخة إلى

/ مدير إدارة التراخيص
/ قسم معدات ومقاولي الإطفاء
/ الملف

